

SCHOOL NAME: A.M.
Cunningham

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Time to Complete Check (Minutes)	Requires Immediate Attention to Maintain Ventilation (Y/N)	Materials	Comments
UV4 change air	CAE1000PAVPD	68410181G	portable4	portable 4	30	Y		no power and wash filter
UV3	CAE1000PAVPF	16460099K	P3	P3	30	Y	1-20X30X1 pltd	need filter rack made or original washables installed
UV1	CAE1000PAVPF	15840026H	P1	P1	30	Y	2-18X16X1 pltd	need correct filters installed and no power
UV2	CAE4036PAERWE	215QE001	P2	P2	30	N		brand new no power to it yet
HRU1 eng air	DJS40C0	M17865HRU1	roof	gym	45	Y	1-BX46, 1-A45* 2-24X24X12 box 2-24X24X2 pltd	Heat pipe actuator shaft out needs install and check needs 1 A45 belt broken and align
DMS	Daikin		east wall	offices	15	N		
RF1	canadian blower		basement	addition	30	Y	2-A48	needs belts , alignment and check noise
SF1			basement	addition	45	Y	2-A32 2-24X24X2 pltd 3-12X24X2 pltd	needs belts , alignment and check noise
W A/C	comfortaire		rm 208	rm 208	15	N		removed and cleaned filter , plugged
EF1	delhi		upper roof	girls w/r	15	Y	1-A47	needs belts , alignment and check noise
EF2	delhi		upper roof	boys w/r	15	Y		needs belts , alignment and check noise