

## ALLAN GREENLEAF SCHOOL

Equipment	Model/Serial	Location	What it Serves	Time Spent	Filters	Belts	Repairs Needed or Repaired
AHU 1	EngAir LM8C / M13882-AHU1		Various Areas	45 min	(3of) 16x20x2 - Pleated (3of) 20x20x2 - Pleated	(1of) B72 (1of) B68	Needs new Belts - Bearings Greased - Completed
HRV-1	EngAir FWB313CO / M13882 HRV1		Gym	45 min	(15of) 20x24x2 - Pleated (3of) 24x24x2 - Pleated	(2of) B85 (2of) BX85	Needs new Belts - Bearings Greased - Completed
RTU 1	EngAir FWA52CO / M13882 RTU 1		Main Offices	45 min	(1of) 24x24x2 - Pleated	(1of) A43 (1of) A35	Belts need to be replaced - Completed
RTU 2	EngAir FWEA62CO / M13882 RTU2			45 min	(1of) 12x24x2 - Pleated (1of) 24x24x2 - Pleated	(1of) A39	Needs new Belts - Bearings Greased - Completed
AHU	ChangeAir CAE1000APA VPD / 1804 1055F	Room 103		30 min	Washable		Electric Heat contactor needs replacing 2 pole 24v coil - Completed
AHU	Changeair CAE100A PA VPD / 1798 1055F	Room 104		30 min	Washable		
AHU	Changeair CAE1000A PA VPD / 1806 1045f	Room 102		30 min	Washable		Heating contactor pitted - Completed
AHU	Changeair CAE 1000A PA VPD / 1799 1055f	Room 101		30 min	Washable		
AHU	Changeair CAE 4036 PA ERWE / 1308 1118E	Room 107		30 min	(2of) 18x18x2 - Pleated		
HRV-1	EngAir LM-15-C / 29538 HRV1			45 min	(16of) 20x25x2 Pleated	(2of) B57 (2of) B63	Replaced B57 Belt - Bearing dry and need greasing - Completed
AHU 1	Engair LM-8-C / 29538 AHU1			45 min	(4of) 20x25x2 Pleated (2of) 16x20x2 Pleated	(2of) B69 (1of) B62	Bearings need to be greased - Heat/Cooling Coil needs to be cleaned - Completed
Fan Coil	TMV 1500 / L4182 A 2		Resource Room	30 min	Washable	(1of) A33	
Fan Coil	JM 2000 / L4182-B3	Library	Computer room	30 min	Washable	(1of) A40	Needs new adjustable Motor Pulley 5/8" shaft x 4" diameter - Completed
Fan Coil	JM 2000 / L4182-B1	Library		30 min	Washable	(1of) A40	Needs new adjustable Motor Pulley 5/8" shaft x 4" diameter - Completed
Fan Coil	JM 2000 / L4182-B3	Library		30 min	Washable	(1of) A40	Needs new adjustable Motor Pulley 5/8" shaft x 4" diameter - Completed
AHU	ChangeAir CAE1000PAVPD / 2397 0267C	Portable 1	Portable 1	30 min	(1of) 16x20x1 Pleated		Unit is extremely drty inside needs to be cleaned - Completed
AHU	ChangeAir CAE1000PAVPD / 2404 0267C	Portable 2	Portable 2	30 min	(1of) 16x20x1 Pleated		Unit is extremely drty inside needs to be cleaned - blower Motor loud on start-up (1/2hp 208/230v 5A 1075 rpm - Completed
Exhaust Fan 1	Greenheck CUBE 140-4 / 00E16120			30 min			No belt on fan - no power to on/off switch - not sue if his is supposed to be off - completed
Fan Coil	Various for classroom						Checked operation - ok

Administrative 45 min