

Univent filter media  
 2 → 77 x 13 x 2  
 16 → 65 x 13 x 2  
 5 → 41 x 13 x 2

4 hrs 2/25

HWDSB	SCHOOL:	Balaclava Elementary school				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Please Note: All univents req' cleaning (vacuum) at Louvres and fans. Comments
univent	Trane	Room 127	Room 127	15/30/45	Y/N	- Filter dirty - checked operation - o.k.
univent	Trane	Room 128	Room 128	15/30/45	Y/N	- Filter dirty - checked operation
univent	Trane	Room 129	Room 129	15/30/45	Y/N	- Filter dirty - checked operation
univent	Trane	Room 130A	Room 130A	15/30/45	Y/N	- Filter clean. - checked operation - o.k.
RTU 2 AHU	Trane (not on list)	Roof	Library Room 117	15/30/45	Y/N	- filters clean; belt, fan - o.k. - checked operation
RTU 1 AHU	D276, 993 ? Trane	Roof	Gym	15/30/45	Y/N	- Blower fan destroyed - Needs replaced as well as bearings + shaft
E.F	Greencheck CW B-240-5-X	Roof GYM WALL	Gym	15/30/45	Y/N	RTU → E.F not coming on in manual or BAS command
E.F	Greencheck CW-098-VG-4-X	Roof GYM WALL	Gym	15/30/45	Y/N	RTU → Perhaps interlocked as part of broken RTU
				15/30/45	Y/N	
				15/30/45	Y/N	
	Trane service literature manual	PCC-M-1		15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

Library Room 117 ATU. Roof - Not on list - No rating plate found.  
 Gym School Power Ventilator (E.F) → Soter + Palau - not on list.  
 ATU Roof - Not on list - No rating plate found.

HWDSB	SCHOOL:	Balaclava Elementary School				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	<p>Please Note: : All units need cleaning (vacuum interior, exterior top).</p> <p>Comments</p>
Univent	Trane	Room 104	Room 104	15/30/45	Y/N	- filters dirty - checked operation - fan bearings noisy o.k.
Univent	Trane	Room 105	Room 105	15/30/45	Y/N	- filter dirty, checked operation - o.k.
Univent	Trane	Room 106	Room 106	15/30/45	Y/N	- filter dirty - checked operation - o.k.
Univent	Trane	Room 107	Room 107	15/30/45	Y/N	- filter dirty - checked operation - o.k.
Univent	Trane	Room 108	Room 108	15/30/45	Y/N	- o.k. - checked operation - Filters clean
Univent	Trane	Room 112	Room 112	15/30/45	Y/N	- o.k. - checked operation - Filters clean
Univent	Trane	Room 116	Room 116	15/30/45	Y/N	- o.k. - Filters clean - checked operation--
Univent	Trane	Room 120	Room 120	15/30/45	Y/N	- filter dirty - checked - operation - o.k.
Univent	Trane	Room 122	Room 122	15/30/45	Y/N	- Filter dirty - - checked operation - o.k.
Univent	Trane	Room 123	Room 123	15/30/45	Y/N	- Filter dirty - checked operation - o.k.
Univent	Trane	Room 124	Room 124	15/30/45	Y/N	- Filter dirty - o.k. - checked operation - Fan high only.
Univent	Trane	Room 125	Room 125	15/30/45	Y/N	- Filter dirty - checked operation - o.k.
Univent	Trane	Room 126	Room 126	15/30/45	Y/N	- Filter dirty, - Checked operation - o.k.
E.F	Greencheck	Roof	Boiler Room	15		- Good
E.F	Greencheck	Roof	washroom	15		- Good
EF	Greencheck	Roof	washroom	15		- Good

HWDSB	SCHOOL:	Balaclava Elementary School				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Chiller Aguasnap	CH-1 Carrier 30MPA04055A10105	Boiler room	School	15/30/45	Y/N	Alarm status present
Chiller Aguasnap	CH-2 Carrier 30MPA04055A10105	Boiler room	School	15/30/45	Y/N	-O.K.
Roof Condenser	Carrier	Roof	School	15/30/45	Y/N	-O.K. visually - awaiting command from unit.
Pump 1	BAS Automation starter	Boiler Room	chiller water	15/30/45	Y/N	-O.K
Pump 2	BAS Automation starter	Boiler Room	chiller water	15/30/45	Y/N	- fault at starter.
Exhaust Fan	Soler + Palau SQB30X H3S	Boiler Room	School Exhaust	15/30/45	Y/N	- checked - O.K. (not on list) - Power ventilator
Univent	Trane	Room 142	Room 142	15/30/45	Y/N	- checked filter, - operation - O.K.
Univent	Trane	Room 140	Room 140	15/30/45	Y/N	- Dirty filter. - operation - O.K. - Noisy fan.
Univent	Trane	Room 139	Room 139	15/30/45	Y/N	- Dirty filter - operation - O.K.
Univent	Trane.	Room 144E	144E	15/30/45	Y/N	- Dirty filter
Univent	Trane	Room 144D	Room 144D	15/30/45	Y/N	- Dirty filter.
Univent	Trane	Room 144B	Room 144B	15/30/45	Y/N	- Filter dirty - NO mod motor for louvres. *
Univent	Trane	Room 143A	Room 143A	15/30/45	Y/N	- Dirty filter

Chiller unit equip