

## BILLY GREEN SCHOOL

Equipment	Model/Serial	Location	What it Serves	Time Spent	Filters	Repairs Needed or Repaired
SF - 1		Mech Room	Mutiple Areas	45 min		
SF - 2		Mech Room	Gym	45 min		automation Programming Issues - Completed
CU - 1	Carrier Model - 38AUDA160A5AOAOAO	Low Roof	Gym	45 min		
Cooling Tower		Mech Room		45 min		Power outlet chemical feeder is tripped and won't reset need to replace - Completed
Heat Pump - 9	MCQuay Model - W.CCW.4.036	Hallway	Room 212	30 min		
Heat Pump - 10	McQuay Model - W.CCW.4.036	Hallway	Room 215	30 min		Off on High Pressure - probably off from recent work on Cooling Tower - Pressures looked good after reset
Heat Pump - 11	MCQuay Model - W.CCW.4.036	Hallway	Room 210	30 min		Off on High Pressure - probably off from recent work on Cooling Tower - Pressures looked good after reset
Heat Pump - 13	MCQuay Model - W.CCW.4.048	Hallway	Room 221	30 min		Off on High Pressure - probably off from recent work on Cooling Tower - Pressures looked good after reset
Heat Pump -14	McQuay Model - W.CCW.4.036	Hallway	Room 205	30 min		Off on High Pressure - probably off from recent work on Cooling Tower - Pressures looked good after reset
Heat Pump - 21	McQuay Model - W.CCW.4.024	Hallway	Library	30 min		Off on High Pressure - probably off from recent work on Cooling Tower - Pressures looked good after reset
Heat Pump - 25	McQuay Model - W.CCW.5.012	Hallway	Room 220	30 min		Off on High Pressure - probably off from recent work on Cooling Tower - Pressures looked good after reset
P - 190	Change Air Model - CAE 1000 PA VPD	Portable 190		30 min		All Contactors 2 pole 240v 40amp 24v coils - Needs Heat & Compressor Contactors
P - 105	Change Air Model - EPA 36-1000-BE	Portable 105		30 min		All Contactors 2 pole 240v 40amp 24v coils - Compressor Contactor completed
P - 306	Change Air EPA 36 1000 BC	Portable 306		30 min		All Contactors 2 pole 240v 40amp 24v coils - Heating Contactor Completed
P	Change Air CAE 1000 PA VPD	Portable		30 min		
P - 5	Change Air AHU005555	Portable S		30 min		All Contactors 2 pole 240v 40amp 24v coils - Compressor Contactor - Completed
P - 262	Change Air EPA 36 1000 BC	Portable 262		30 min		All Contactors 2 pole 240v 40amp 24v coils - Heat Contactor - Completed
P - 172	Change Air EPA 36 1000 BC	Portable 172		30 min		All Contactors 2 pole 240v 40amp 24v coils - Contactors one for all 3 stages of heat - filters are 16x20x1 (2of) - Completed
EF - 135	Powair-X-Hauster	Low Roof	First Floor	15 min		Looks like they have not ran for years - Custodiam does't know where switches/breakers are for them - Completed
EF - 136	Powair-X-Hauster LO12	Low Roof	First Floor	15 min		
EF - 137	Powair-X-Hauster LO1806	Low Roof	First Floor	15 min		
EF - 138	Powair-X-Haustr / 1508	High Roof	2nd FL Washroom	15 min		Needs new pillow block bearing 5/8 shaft mounting holes 3" center shaft distance from support 1" centre - Completed
EF - 139	Power Ventilator	High Roof	2nd FL Kitchen	15 min		
EF - 140	Power Ventilator SDBD12MM1AS	High Roof	Gym	15 min		

Administrative 45 min