

SCHOOL NAME: Dalewood

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Check (Minutes)	Immediate	Materials	Comments
HRU1 eng air	FWE183DJS600	M16909HRU1	east roof	east bldg	45	N	2-20X25X2 pltd	
CU1	SUZKA15NA Mits		east roof	offices	15	N		
CU2	SUZKA12NA		east roof	offices	15	N		
CU3	SUZKA15NA		east roof	offices	15	N		
CU4	SUZKA09NA		east roof	offices	15	N		
SF3	CSC2V18		penthouse mech	bldg	45	N	16-20X20X2 pltd	
EF4	CSC		penthouse mech	bldg	15	N	1-A58	
CU5	SUZKA15NA		roof	offices	15	N		
CU6	SUZKA15NA		roof	offices	15	N		
CU7	AK12NMVJU Daikin		roof	offices	15	N		
HRU2 eng air	FWE183DJS600	M16909HRU@	west roof	west bldg	45	N	3-20X20X2 pltd	
RTU1	YHD180GW trane	154810205D	west roof	gym	45	Y	4-16X20X2 pltd	no fresh air and econo filter faulty