

3/15 Alan T...

HWDSB	SCHOOL:	Earl Kitchener				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
	Earl Kitchener school			15/30/45	Y/N	
RTU	Lennox LGC180S2BM21	Roof	Rm-021 Gym	15/30/45	Y/N	
A/c	America Series EMI	window	Room 006	15/30/45	Y/N	Filter dirty.
A/c F.C	Lennox CB29M	Window Room 120B	office staff Rm	15/30/45	Y/N	
RTU.		Roof	Tempered air. Full building	15/30/45	Y/N	→ Filters dirty need 11 → 18x25x2
				15/30/45	Y/N	
	Mary Hopkins School (cont'd)			15/30/45	Y/N	
				15/30/45	Y/N	
Unit ventilator	Series 1100 Change Air			15/30/45	Y/N	- cleaned filters
Unit ventilator	Series 1000 Change Air			15/30/45	Y/N	- cleaned filters
Unit ventilator	sophomore Series Change Air.			15/30/45	Y/N	- cleaned filters
				15/30/45	Y/N	
				15/30/45	Y/N	

Sept 3 1hr

HWDSB	SCHOOL:		Earl Kitchener.			
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
E.F	Greencheck SWB-115-15-CW-74X	Roof	Boys Washroom	15/30/45	Y/N	- checked operation → o.k
AHU(ERV)	Lennox	Roof	School	15/30/45	Y/N	- checked operation, checked belts, checked Filters (Dirty)
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

filters.