

Centre

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Complete	Immediate	Materials	Comments
AHU 101	AIRPAK HAAKON	13-7648-002-K	Mech Rm 402	Building	45	N	12x24X2 pl 3	Changed 2" Filters
RF 201	QE1-30-1-50-X Greenheck	13471363	South Mech Rm 402	AHU 101	45	N	A77 x2	
AHU 102	AIRPAK HAAKON	13-7648-003-K	South Mech Rm 402	Building	45	N	12x24x2 pl 6	Changed 2" Filters
RF 202	QE1-30-1-50-X Greenheck	13471364	South Mech Rm 402	AHU 102	45	N	A76 x2	
AHU 103	AIRPAK HAAKON	13-7648-004-K	South Mech Rm 402	Building	45	N	12x24x2 pl 2	Changed 2" Filters
RF 203	QE1-24-1-20-X Greenheck	13471365	South Mech Rm 402	Building	45	N	AX62	
AHU 104	AIRPAK HAAKON	137648-005K	South Mech Rm 402	Building	45	N	24x24x4 pl 6	changing
RF 204	7648-(K005)-AHU-104RF HAAKON		South Mech Rm 402	AHU 104	45	N	B68 x2	
EF03	CUBE-161XP-15-6	13462783	South Roof	Kitchen	15	N	A21	Belt Loose/Cracked. Replaced with Spare on site
EF04	GB-200-10-X	13462784	South Roof	Print Room	15	N	AX29	Belt Loose/Cracked. Replaced with Spare on site
EF05	CUE-075-V6-6-X	13462785	South Roof	Building	15	N		
EF06	GB-161-7-X	13462786	South Roof	Washrooms	15	N	A20	Belt Loose/Cracked. Replaced with Spare on site
EF07	CUBE-141HP-4-X	13462787	South Roof	Building	15	N	3L190	Belt Loose/Cracked. Replaced with Spare on site
EF08	GB-071-4-X	13462788	South Roof	Building	15	N	3L180	Belt Loose/Cracked. Replaced with Spare on site
EF01	GB-081-4-X	13462781	North Roof	Building	15	N	3L190	Belt Loose/Cracked. Replaced with Spare on site
EF02	GB-180-10-X	13462782	North Roof	Washrooms	15	N	A25	Belt Loose/Cracked. Replaced with Spare on site
RF 210	QE1-24-1-30-X	13471370	North Mech Room	AHU 110	45	N	A64 x2	
AHU 110	AIRPAK HAAKON	13-7648-006-K	North Mech Room	Building	45	N	12x24x2 pl 4	2" Filters changed
RF 205	QE1-24-1-30-X	13471366	North Mech Room	AHU 105	45	N	A63 x2	
AHU 105	AIRPAK HAAKON	13-7648-006-K	North Mech Room	Building	45	N	12x24x2 pl 4	
RF 206	QE1-27-1-30-X	13471367	North Mech Room	AHU 106	45	N	A70 x2	
AHU 106	AIRPAK HAAKON	13-7648-007-K	North Mech Room	Building	45	N	24x24x4 pl 4	
RF208	7648-(K009)-AHU-108RF	13499776-10-1	North Mech Room	AHU 108	45	N	3VX800 x3	
AHU 108	AIRPAK HAAKON	13-7648-001K	North Mech Room	Building	45	N	12x24x2 pl 5	Supply air 2" filters changed. All others clean
RF 207	QE1-24-1-30-X	13471368	North Mech Room	AHU 107	45	N	A64 x2	
AHU 107	AIRPAK HAAKON	13-7648-008-K	North Mech Room	Building	45	N	12x24x2 pl 2	Changed 2" filters