



3-35 Stonechurch Rd, Suite 217, Ancaster, ON L9K 1S4  
tel: 905-577-0111 ■ office@mesl-hvac.ca

[mesl-hvac.ca](http://mesl-hvac.ca)

September 11, 2020

Elizabeth Bagshaw School  
350 Albright Road  
Hamilton ON L8K 5J4

Michael Sokolowski:

Inspection and deficiencies of the ventilation systems for this site have all been repaired and/or completed. Units are all running according to the manufacturer's specifications, with the following exceptions below:

F3- Cafeteria – work to be completed: replace fan bearings – this unit is still operational

Thank you,

Mike Cuffaro, President  
Moore Environmental Systems Limited