

Bagshaw

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Complete Check	Immediate	Materials	Comments
Unknown, RTU	48HCFD28ACA10B0A0	3615P24055	Roof	Building	45	N	16x25x2(9) BX44(1)	
Unknown, RTU	48HCFD28ACA10B0A0	4415P25582	Roof	Building	45	N	16x25x2(9) BX44(1)	
Unknown, EF	Unknown	Unknown	Roof	Building	15	N	4L210(1)	
Unknown, EF	Unknown	Unknown	Roof	Building	15	Y	Unknown	Belt Needed
XF43	Unknown	Unknown	2 Floor Mechanical Room	Building	45	Y	A57(2)	Belt Needed
XF19	Unknown	Unknown	2 Floor Mechanical Room	Building	45	Y	4L570(2)	Belt Needed
Unknown, Fan	Unknown	Unknown	2 Floor Mechanical Room	Building	45	Y	4L330(1)	Belt Needed
Unknown, Fan	Unknown	Unknown	West Mechanical Room	Building	45	Y	16x25x2(10) B66(2)	Motor Bearings
Unknown, Fan	Unknown	Unknown	West Mechanical Room	Building	45	N	16x25x10(8) B66(2)	
F3, Fan	Unknown	Unknown	East Mechanical Room	Cafeteria	30	N	16x25x2(8) BX73(2)	Fan Bearings
F7, Fan	Unknown	Unknown	East Mechanical Room	Cafeteria Return	30	N	A50(1)	
F1, Fan	Unknown	Unknown	East Mechanical Room	Supply Area C	30	N	16x25x2(10) AX78(2)	
F2, Fan	Unknown	Unknown	East Mechanical Room	Locker Room	30	N	20x24x2(6) B70(2)	
F13, Fan	Unknown	Unknown	East Mechanical Room	Washroom Exhaust	30	N	Unknown	
F8, Fan	Unknown	Unknown	East Mechanical Room	Locker Room	30	N	Unknown	
F21, Fan	Unknown	Unknown	Basement North Mechanical Room	North Wing Supply	30	N	16x20x2(12)B70(3)	
Unknown, EF	Unknown	Unknown	Boiler Room	Boiler Room	15	N		
Unknown, EF	Unknown	Unknown	Boiler Room	Chiller Room	15	Y	A32(1)	Motor Bearing, Belt Needed