

SCHOOL: FRANKLIN ROAD - 500 FRANKLIN ROAD
 JOB: TMR-1749-04

UNIT TYPE AND TAG	MODEL	SERIAL	FILTERS	BELTS	UNIT LOCATION	SERVES	TIME TO COMPLETE	REQUIRES IMMEDIATE ATTENTION	NOTES
P184	MCV850	10089175 D	WASHABLE FILTER					A/C has no condensing unit (refrig. Lines cut)	DIRECT DRIVE BLOWER
2ND Portable	CAE 1000 PA VP D	6842 0181G	WASHABLE FILTER						DIRECT DRIVE BLOWER
PU 1	48HCED11A2A1A0A0G0	3317P99925	(4) 20X20X2 PL	AX49		GYM			No power at unit, maintenance did not know anything about it or the whereabouts of the breaker panel
PU 2	48HCED11A2A1A0A0G0	3317P99924	(4) 20X20X2 PL	AX49		GYM			
	3 50TFF006-P-311R0	3403G40423	(2) 16X25X2 PL	A40		OLD AUDITORIUM			(mechanical cooling only, ducted heating hydronic coils)
	4 50TFF006-A-311RQ	3403G40424	(2) 16X25X2 PL	A40		OLD AUDITORIUM		Compressor not running on command.	(mechanical cooling only, ducted heating hydronic coils)
FAN	HRV 2000E EBA1XG12DNHDBS	6K8220030801448	2) 12X24XX	B38		AUDITORIUM			
5 OFFICE	50GS-024-301	3003G12203	(2) 12X20X2 PL			OFFICE			DIRECT DRIVE
PU3	48HCED07A1A1A0A0A0	3317P40052	(2) 16X20X2 PL	AX44		DAYCARE			NEWER UNIT (Mechanical cooling/heating)
PU4	48HCED08A2A1A0A0A0	2517P32140	(4) 20X20X2 PL	A48		DAYCARE			NEWER UNIT (Mechanical cooling/heating)
EF-1	G-131-VG-X	12172826 1007							Dome Style
EF-2	G-101-VG-X	12172827 1007							Dome Style
EF-6	G-101-VG-X	12172831 1007							Dome Style
EF-5	G-080-DGEX-RD	12783821 1203							Dome Style
EF-4	G-121-VG-X	12172829 1007							Dome Style
EF-3	G-131-VG-X	12172828 1007							Dome Style
EF-7	G-131-VG-X	121723832 1007							Dome Style
EF-8	G-090-BG-X	12172833 1007							Dome Style
EF-9	G-090-VG-X	12172834 1007							Dome Style
EF-10	G-170-B-X	12172835 1007							Dome Style
EF-11	G-095-VG-X	12172834 1007							Dome Style
EF 1,2,3,4 &5	GB-081-6	03H06110		3L170					
EF 1,2,3,4 &5	GB-081-6	03H06113		3L170					
EF 1,2,3,4 &5	GB-081-6	03H06112		3L170					
EF 1,2,3,4 &5	GB-081-6	03K06114		3L170					