

SCHOOL NAME: Glen Echo

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Complete	Immediate	Materials	Comments
Unknown, Window AC Unit	RADS-12J	2025871813319151969	Computer Lab	Computer Lab	15	N	Washable Filters	Cleaned
Unknown, Window AC Unit	RADS-12J	2025871813318151037	Computer Lab	Computer Lab	15	N	Washable Filters	Cleaned
Unknown, Window AC Unit	CW-1000Fk	1195801361	Room 113	Room 113	15	N	Washable Filters	Cleaned
Unknown, Window AC Unit	CW-1000Fk	11958013	Room 113	Room 113	15	N	Washable Filters	Cleaned
Unknown, EF	Unknown	Unknown	Roof Central	Building	15	N		
Unknown, EF	Unknown	Unknown	High Roof	Building	15	N	A33(1)	Belt Needed
Unknown, EF	Unknown	Unknown	High Roof	Building	15	N	A33(1)	Belt Needed
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N	3L180(1)	Belt Needed
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N		
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N		
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	West Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N	3L180(1)	Belt Needed
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15	N		Not Operable