

SCHOOL NAME: Glendale

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Complete	Immediate	Materials	Comments
AHU1, RTU	48TJD016510QA	1996F06106	NW Roof	Building	45	Y	16x20x2(4) 20x20x2(4) B41(1)	Filters/Belt/Economizer Filter
Unknown, RTU	DPS020AHMG5DW-4	FBOU19090287	NW Roof	Building	45	N	16x25x2(9)	Filters, Needed
Unknown, RTU	DPS028AHMG5DW-4	FBOU190902086	NW Roof	Building	45	N	16x25x2(9)	Filters Needed
AHU5, RTU	YCD090CWHABE	M28103921D	Central Roof	Building	45	N	16x25x1(3) A45(1)	Filters Done, Belts Needed
AHU7, RTU	TBA250/DX-C20	CN-895AHU7	Central Roof	Building	45	Y	B68(2)	Filters, Belts Needed
AHU8, RTU	TBA250/DXC20	CN895AHU8	Central Roof	Building	45	N	B70(2)	Filters, Belts Needed
HVAC1, RTU	48TJE006—501QE	3395G28222	Roof East	Building	45	N	16x25x2(2) A40(1)	Filters Needed
HVAC2, RTU	48TJE006—501QE	3395G20223	Roof East	Building	45	N	16x25x2(2) A40(1)	Filters Needed
HVAC3, RTU	48TJE006—501QE	2996G20720	Roof East	Building	45	N	16x25x2(2) A40(1)	Filters Needed
AHU10, RTU	TBA300/DX-C25	CN-895AHU10	Roof East	Building	45	Y	B62(1)	Filters Done, Belts Needed
AHU9, RTU	YCD090CWHABE	M28103919D	Roof East	Building	45	Y	16x25x1(3) A45	Filters Done, Belts Needed
AHU12, RTU	YCD090CWHABE	M28103920D	Roof East	Building	45	N	16x25x1(3) AX45	Filters Done, Belts Needed
AHU11, RTU	TBA250/DXC20	CN-895AHU11	Roof East	Building	45	N	B64(1)	Filters Needed
EF-TE1, EF	6B-180-7-X	1.1535E+11	Roof East	Building	15	Y	AP29	Belt Needed
EF-STE, EF	6B-131-3-X	1.1535E+11	Roof East	Building	15	Y	4L270	Belt Needed, Not Operable
EF-EE, EF	SWB-212-20-CW-TH-X	1.15342E+11	Roof East	Building	15	N	AP29	Not Operable
HVAC101,RTU	FWE453/DJS100/0	M19400 HVAC-101	Lower Roof	Building	45	N	B84(2)	Filters Done
AHU4,RTU	YCD180BWLAEA	M29101788D	Lower Roof	Building	45	N	20x25x2(4) 20x20x2(2)BX62(10	Filters Done
KEF-1, EF	CUBE-180-15-G	96H05161	Lower Roof	Building	15	N	A24	Not Operable
KSF-1, EF	RSF-120-7	96H06314	Lower Roof	Building	15	N	A43	Not Operable ,Belt Needed
EF-13,EF	6B-101-3-X	1.1535E+11	Lower Roof	Building	15	Y	Unknown Belt	Not Operable, Belt Missing, Motor Bearings
Unknown, EF	Unknown	Unknown	Lower Roof	Building	15	N	B22	Not Operable
EF-HE2, EF	CUBE-121-5-6	1.1535E+11	Roof East	Building	15	N	AX21	Not Operable
EF-HE1, EF	CUBE-121-5-6	1.1535E+11	Roof East	Building	15	N	AX23	Not Operable
Unknown, HP	4MXS32GVJU	E015286	Roof East	Building	30	N	Washable Filters	Not Operable
EF-18,EF	GB-200-15	96H05933	Roof East	Building	15	Y	4L270	Broken Belt, Not Operable
EF-17	GB-80-4	96H06570	Roof East	Building	15	N	4L180	Worn Belt, Needs Adjustment, Not Operable
Unknown, EF	GB-140-3X-QD	95G04739	Roof Central	Building	15	N	3L210	Not Operable
EF-15, EF	GB-140-7	96H05697	Roof Central	Building	15	Y	A24	Not Operable, Belt Broken
EF-8:9, EF	FX13QGP	J19AB94713	Roof Central	Building	15	N		Not Operable
EF-7, EF	FX11QGP	J19AB94711	Roof Central	Building	15	N		Not Operable
EF-8/9, EF	FX13QGP	J19AB94712	Roof Central	Building	15	N		Not Operable
EF-14, EF	GB-160-7	96H05759	Roof West	Building	15	N	A24(1)	Not Operable, Belt Needed
Unknown EF,	Unknown	Unknown	Gym Mechanical Room	Gym	15	N	B-114(2)	Belts Needed
Unknown, MUA	Unknown	Unknown	Gym Mechanical Room	Gym	45	N	16x25x2 (M)(9) B108(2)	Belts Needed, Filters done
Unknown, EF	Unknown	Unknown	Gym Mechanical Room	Gym	15	N	A52(2)	Belts Needed
Unknown, MUA	Unknown	Unknown	Gym Mechanical Room	Gym	45	N	20x20x2 (M)(6)AX90	
Unknown, MUA	Unknown	Unknown	Gym Mechanical Room	Shop	45	N	20x25x2(9)(M) B136(2)	Filters done
Unknown EF, EF	Unknown	Unknown	Gym Mechanical Room	Shop	15	Y	B78(2)	Belts Needed
Unknown, FC	40RM-007—B611HC	3809U2099	Dance Classroom Storage	Dance Classroom	30	N	16x24x2(4) A41(1)	Filters Needed
Unknown, EF	Unknown	Unknown	Dance Classroom Storage	Dance Classroom Storage	15	N	4L490(1)	
Unknown, EF	Unknown	Unknown	East Low Roof	Building	15	N		
Unknown, EF	Unknown	Unknown	East Low Roof	Building	15	N		