

HWDSB	SCHOOL:		Green Acres ELF			
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
RTAC-1	Trane YCH150D3HBBB	Roof	Library	15/30/45	Y/N	Belts, filters, bearings OK needs clean checked operation - OK repair
RTU-1	Trane YHCO3GE3RXAO	Roof	Office	15/30/45	Y/N	Belts, filters, bearings OK checked operation - OK
HVAC	Eng air DJX40/0	Roof Gym	Gym	15/30/45	Y/N	Changed Belts - Belts on site Filters OK Bearings OK operation - OK
UV	Trane Change air	RM 130	Staffroom	15/30/45	Y/N	Filters OK, checked operation - OK
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

HWDSB	SCHOOL:	Green Acres EIE				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
RTA-C-1	Trane YCH150B3HBBB	Roof	Library	15/30/45	<input checked="" type="checkbox"/> Y/N	Belts, Filters & Bearings OK needs clean Belt pulley operation - OK repair Belt filters, bearings OK
RTU-1	Trane YHC031E3RXAD	Roof	Office	15/30/45	<input checked="" type="checkbox"/> Y/N	Checked operation - OK
HVAC	Eng air DX4010	Roof Gym	Gym	15/30/45	<input checked="" type="checkbox"/> Y/N	Changed Belts - Belts on site Filters OK Bearings OK operation - OK Filters OK, checked operation - OK
UV	Trane Ultrage air	RM 130	Staffroom	15/30/45	<input checked="" type="checkbox"/> Y/N	Direct Drive Running OK
EF	Greenheck 6099 Y6X	Roof	EFC3	15/30/45	<input checked="" type="checkbox"/> Y/N	"
EF	Greenheck 6085 Y6X	Roof	EFW2	15/30/45	<input checked="" type="checkbox"/> Y/N	"
EF	Greenheck 6143 Y610X	Roof	EF-C2	15/30/45	<input checked="" type="checkbox"/> Y/N	"
EF	Greenheck 6085 Y6X	Roof	EFW-1	15/30/45	<input checked="" type="checkbox"/> Y/N	"
EL	Greenheck 6060 G-X	Roof	EFG-2	15/30/45	<input checked="" type="checkbox"/> Y/N	"
EF	Greenheck 6080 G-X	Roof	EFF-1	15/30/45	<input checked="" type="checkbox"/> Y/N	"
EF	Greenheck G-123 Y6X	Roof	EFW3	15/30/45	<input checked="" type="checkbox"/> Y/N	"
EF	Greenheck G-143 Y6X	Roof	EFC1	15/30/45	<input checked="" type="checkbox"/> Y/N	"