

GUY BROWN SCHOOL

Equipment	Model/Serial	Location	What it Serves	Time Spent	Filters	Belts	Repairs Needed or Repaired
AHU 1	Trane CSAA014UAC00 / K10M12512A			60 min	(6of) 20x20x2 Pleated (2of) 20x25x2 Pleated	(1of) BX43 (1of) B41	Replaced Belt
ERV 1	EngAir DJS100-0 / M13730 ERV1			60 min	(4of) 20x20x2 Pleated (4of) 16x20x2 Pleated (6of) 24x24x2 Pleated	(2of) B80 (2of) B77	Supply & returning fan belts need replacing - greased bearings - Completed
Exhaust Fan 12	Pennbarry FX18V / E11AE38799			30 min			Bearings gone on motor needs to be replaced - Completed
FCU 5	EngAir JM1000 / Q1413-FC-6		Room 223	30 min	(1of) 16x25x2 Pleated	(1of) A33	
FCU 6	EngAir JM1000 / Q1413-FC-6		Room 225	30 min	(1of) 16x25x2 Pleated	(1of) A33	
FCU 7	EngAir JM700 / NA		Room 234	30 min	(1of) 16x20x2 Pleated	(1of) A32	Replaced Belt
FCU 8	EngAir JM100 / P1413-FC-8		Room 226	30 min	(1of) 16x25x2 Pleated	(1of) A35	Replaced Belt
AHU	Whispair 1100 / 6-008-493	Portable 401	Portable 401	30 min	Washable		Compressor Contactor Burnt & needs replacing (2pole 24V coil) - Completed
AHU	Whispair 1100 / 6-008-495	Portable 402	Portable 402	30 min	Washable		Drain plugged - removed and cleaned
AHU	ChangeAir CAE1000A PA VP D / 1363 1272B	Portable 403	Portable 403	30 min	(2of) 16x20x1		
FC	EngAir JM1000 / Q1413-FC-16	Room 204	Room 204	30 min	(1of) 16x25x2 Pleated	(1of) A33	
FC	EngAir JM1000 / Q1413-FC-17	Room 204	Room 204	30 min	(1of) 16x25x2 Pleated	(1of) A35	
FC	EngAir JM1000 / Q1413-FC-16	Room 204	Room 204	30 min	(1of) 16x25x2 Pleated	(1of) A37	

Administrative 30 min