

HWDSB	SCHOOL:	Helen Detweiler ELIZ				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Chiller	Carrier Chiller 30HX186R2-101KA	Mech. Room	School	15/30/45	Y/N	Checked operation - OK
Cooling Towers	BAC VIL-185MP	Roof	Schools	15/30/45	Y/N	Checked Tower operation - OK
HVAC	Trane Change air	Portapak Room	Classroom #20	15/30/45	Y/N	Filters OK (wrong direction) Checked operation - OK
HVAC	Trane Change air	"	#21	15/30/45	Y/N	" Checked operation - OK
HVAC	"	"	#22	15/30/45	Y/N	" AC not working
HVAC	"	"	#23	15/30/45	Y/N	" Checked operation - OK
HVAC	"	"	#24	15/30/45	Y/N	" "
HVAC	"	"	#25	15/30/45	Y/N	" "
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	