

SCHOOL: HESS STREET - 107 HESS STREET NORTH
 JOB: TMR-1749-07

UNIT TYPE AND TAG	MODEL	SERIAL	FILTER	BELTS	UNIT LOCATION	SERVES	TIME TO COMPLET	REQUIRES IMMEDIATE ATTENTION	NOTES
SF #1	FWA224/CM/0	46987 SF-1	(4) 24X24X2 pl	SF - B74 / RF B60	Front of Building closest to doors	mechanical cooling and hydronic heating			
SF #2	FWA224/C/0	M13680 SF-2	(2) 20X202 PL / (2) 20X25X2 PL	SF- B39 / RF- B50	Middle of building	mechanical cooling only		Stage 1 flashing quite a bit at site glass.	
SF #3	FWA285/CM/0	46987 SF-3	(6) 24x24x2 PL	SF (2) -B63 / RF (2) BX94	Rear right from front of bldg	mechanical cooling and hydronic heating		one compressor completely covered in oil	
SF #4	FWA224/CM/0	46987 SF-4	(4) 24X2422 PL	SF - B59 / RF B74	Rear left from fron of bldg	mechanical cooling and hydronic heating		Cooling coil iced up	
SF #5	LM6/C/0	M13680 SF-6	(4) 20X25X2 PL	SF - B78 / RF- B59	Front left unit	Hydronic heat only			
				Dome Exhaust Fan 1					Off on automation
				Dome Exhaust Fan 2					Off on automation
				Dome Exhaust Fan 3					Off on automation
				Dome Exhaust Fan 4					Off on automation