SCHOOL NAME: Highview

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Check (Minutes)	Immediate	Materials	
Unknown, EF	Unknown	Unknown	Roof	Building	15 N		B33	Belt Needed, Not Operable
Unknown, RTU	48TFF006-A-111RS	3303G20167	Roof	Building	45 N		16x25x2(2) A41(1)	•
Unknown, RTU	48TFF006-A-111RS	3303G20166	Roof	Building	45 N		16x25x2(2) A41(1)	
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N		Unknown	
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	South Roof	Building	15 N			Not Operable
Unknown, EF	Unknown	Unknown	East Roof	Building	15 N		3L310(1)	Not Operable
Unknown, EF	Unknown	Unknown	East Roof	Building	15 Y		A58(1)	
Unknown, EF	Unknown	Unknown	East Roof	Building	15 N			Not Operable
FC	40QHS048320	1789H06154	Library	Library North	30 N		24x24x1(1)(W)	
UV	Unknown	Unknown	Library)	Library South	30 N		16x16x1(2)	Filters Done
Unknown, HP	Unknown	Unknown	Room 131	Room 131	30 N		7x30(1)	Filter Done
Unknown, HP	Unknown	Unknown	Room 131	Room 131	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 130	Room 130	30 N		7x30(1)	Not operable
Unknown, HP	Unknown	Unknown	Room 130	Room 130	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 110	Room 110	30 N		7x30(1)	Filter Done
Unknown, HP	Unknown	Unknown	Room 110	Room 110	30 N		7x30(1)	Not Operable
Unknown, HP	Unknown	Unknown	Room 109	Room 109	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 109	Room 109	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 206	Room 206	30 N		7x30(1)	Not Operable
Unknown, HP	Unknown	Unknown	Room 206	Room 206	30 N		7x30(1)	Filter Done
Unknown, HP	Unknown	Unknown	Room 207	Room 207	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 207	Room 207	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 210	Room 210	30 N		7x30(1)	No Filter
Unknown, HP	Unknown	Unknown	Room 210	Room 210	30 N		7x30(1)	No Filter
Unknown, HP	Unknown	Unknown	Room 218	Room 218	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 218	Room 218	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 219	Room 219	30 N		7x30(1)	Not Operable
Unknown, HP	Unknown	Unknown	Room 219	Room 219	30 N		7x30(1)	Not Operable
Unknown, HP	Unknown	Unknown	Room 219	Room 219	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 219	Room 219	30 N		7x30(1)	Not Operable
Unknown, HP	Unknown	Unknown	Room 221	Room 221	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 221	Room 221	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 221	Room 221	30 N		7x30(1)	
Unknown, HP	Unknown	Unknown	Room 127	Room 127	30 N		7x30(1)	