

| HWDSB | SCHOOL: | JANET LEE ELE | | | | |
|--|--------------------|--|---|----------------------------------|--|---|
| Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.) | Model | Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.) | Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.) | Time To Complete Check (minutes) | Requires Immediate Attention to maintain ventilation | Comments |
| AHU | N/A | Gym Roof | Gym | 15/30/45 | <input checked="" type="checkbox"/> Y/N | Filters plugged, grease spots leaking |
| AHU | TRANE | Boiler room | School | 15/30/45 | <input checked="" type="checkbox"/> Y/N | 2-BX 75 Belts, no filters leaking (see log) |
| Chiller | York YLAA00805E28X | Roof | School | 15/30/45 | <input checked="" type="checkbox"/> Y/N | Chiller operation OK |
| Univent | Trane Univent | Classroom | Rm 133 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | filters changed, checked operation - OK |
| " | " | " | Rm 135 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 128 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 127 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 126 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 125 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 124 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 123 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 122 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |
| " | " | " | Rm 117 | 15/30/45 | <input checked="" type="checkbox"/> Y/N | " |

HVAC Unit TRANE Classroom Portable 30 Y N

Filters installed, no filters were in this unit used 3-12x20x1 PL Filters

HWDSB

SCHOOL:

Tanet Lee ELI

| Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.) | Model | Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.) | Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.) | Time To Complete Check (minutes) | Requires Immediate Attention to maintain ventilation | Comments |
|--|---------------|--|---|----------------------------------|--|--|
| Univent | Trane Univent | Classroom | RM 113 | 15/30/45 | Y/N | NEEDS Filter Checked operation - OK |
| " | " | " | RM 109 | 15/30/45 | Y/N | " |
| " | " | " | RM 108 | 15/30/45 | Y/N | " |
| " | " | " | RM 107 | 15/30/45 | Y/N | " |
| " | " | " | RM 106 | 15/30/45 | Y/N | Filter Changed |
| " | " | " | RM 105 | 15/30/45 | Y/N | Needs Filter |
| " | " | " | RM 102 E | 15/30/45 | Y/N | Filter Changed |
| " | " | " | RM 102 D | 15/30/45 | Y/N | " |
| " | " | " | RM 102 B | 15/30/45 | Y/N | Needs Filter |
| " | " | " | RM 146 A | 15/30/45 | Y/N | " |
| " | " | " | RM 145 | 15/30/45 | Y/N | " |
| " | " | " | RM 143 | 15/30/45 | Y/N | " |
| " | " | " | RM 142 | 15/30/45 | Y/N | " |