

HWDSB	SCHOOL:	WAKE AVE ELE.				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Ductless Split	PKA-A30KA7	Rm 115	Staffroom	15/30/45	Y/N	Washed Filters, Checked operation Drain has condensation on it (should be insulated)
Ductless Split	PKFY-PISNHMU-E2	Rm 121	Principals office	15/30/45	Y/N	Washed Filters, Checked operation
Ductless Split	PKFY-PISNHMU-E2	Rm 122	Main office	15/30/45	Y/N	Washed Filters, Checked operation
AHU	AH-1 GYM	Gym Storage	GYM	15/30/45	Y/N	NEEDS 6-16x25x2 PL Filters 2-364 Belt Unit is leaking water from A/C coil
DX AHU	Trane 4TEH3F36B1000AB	Library Ceiling	Library	15/30/45	Y/N	Needs 1-20x20x1 PL Filter A/C water leak onto ceiling
DX AHU	Trane 4TEH3F36B1000AB	Library Ceiling	Library	15/30/45	Y/N	Needs 1-20x20x1 PL Filter A/C water leak onto ceiling
HVAC	Trane Changeair Unit	Classroom	Portable	15/30/45	Y/N	Washed out filter, Check operation
HVAC	Trane Changeair Unit	Classroom	Portable	15/30/45	Y/N	Needs 2-16x20x1 PL Filters Checked operation - OK
HVAC	Trane Changeair Unit	Classroom	Portable	15/30/45	Y/N	Needs 2-16x20x1 PL Filters Checked operation - OK
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

HWDSB	SCHOOL:	Lake Ave				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
AH EF	mod L01206	roof	Class room	15/30/45	Y/N	
AH EF	mod L01807	roof	Class room	15/30/45	Y/N	
AH EF	mod L01206	roof	Class Room	15/30/45	Y/N	
AH EF	mod L01807	roof	Class Room	15/30/45	Y/N	
AH EF	mod L01206	roof	Class Room	15/30/45	Y/N	
AH EF	mod L01807	roof	Class Room	15/30/45	Y/N	
HVAC	Engineered Air	Roof	Office	15/30/45	Y/N	12 - 20x20x2
HVAC	Engineered Air	Roof	Office	15/30/45	Y/N	3 - 20x24x2 3 - 24x24x2
HVAC	Engineered Air	roof	Office	15/30/45	Y/N	6 - 20x20x2
AHU		Gym	Gym	15/30/45	Y/N	6 - 16x25x2 2-Belts
Air Conditioning		Library	Library	15/30/45	Y/N	2 - 20x20x1
HVAC	CHANGE AIR CAH 2000HNAERWF	Class 176	Class Room	15/30/45	Y/N	1 - 20x20x1 1 - 20x12x1
HVAC	Change Air CAH 2000HNAERWF	Class 175	Class Room	15/30/45	Y/N	1 - 20x20x1 1 - 20x12x1

[illegible]

HWDSB		SCHOOL:	WAKE AVE ELE.			
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Ductless Split	PKA-A30KAT7	Rm 115	Staffroom	15/30/45	Y/N	Washed Filters, Checked operation Drain has condensation on it (insulated)
Ductless Split	PKFY-P15NHUVEZ	Rm 121	Principal's office	15/30/45	Y/N	Washed Filters, Checked operation
Ductless Split	PKFY-P18NHUVEZ	Rm 122	Main office	15/30/45	Y/N	Washed Filters, Checked operation
AHU	AH-1 GYM	Gym Storage	GYM	15/30/45	Y/N	NEEDS 6-16x25x2 PL Filters 2-Red Belt Unit is leaking water from A/C coil
DX AHU	Trane 4TEH3F36B100DAB	Library Ceiling	Library	15/30/45	Y/N	Needs 1-20x20x1 PL Filter A/C water leak onto ceiling
DX AHU	Trane 4TEH3F36B100DAB	Library Ceiling	Library	15/30/45	Y/N	Needs 1-20x20x1 PL Filter A/C water leak onto ceiling
HVAC	Trane Changelair Unit	Classroom	Portable	15/30/45	Y/N	Washed out Filter, Check operation
HVAC	Trane Changelair Unit	Classroom	Portable	15/30/45	Y/N	Needs 2-16x20x1 PL Filters Checked - OK
HVAC	Trane Changelair Unit	Classroom	Portable	15/30/45	Y/N	Needs 2-16x20x1 PL Filters Checked - OK
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	