

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
AHU	Trane	Music Mech room	Pool	15/30/45	Y/N	Change filters, checked Belts grease bearing
Univent	Commander aire	Offices	Guidance 1011	15/30/45	Y/N	Change filters, checked operation oiled motors
u	u	u	u 1011	15/30/45	Y/N	u
u	u	u	u 1011	15/30/45	Y/N	u
u	u	u	u 1011	15/30/45	Y/N	u
u	u	u	u 1011	15/30/45	Y/N	u
u	u	u	u 1011	15/30/45	Y/N	u
u	u	u	u 1011	15/30/45	Y/N	u
Univent	Eng Air VUV 1200	room	Weight Room	15/30/45	Y/N	u
u	Eng "	room	Weight Room	15/30/45	Y/N	u
Univent	Eng Air vus 800	Lounge	1048	15/30/45	Y/N	u
u	u	Lounge	1048	15/30/45	Y/N	u
u	Eng Air VUV 1200	Classroom	1090	15/30/45	Y/N	u

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Univent	Eng Air VUV 1200	Classroom	2024	15/30/45	Y/N	Changed Filters, Checked operation oil motors
Univent	2-Eng Air VUV 1200	"	2019	15/30/45	Y/N	one ceiling mount, one on wall "
Univent	"	"	2028	15/30/45	Y/N	"
Univent	"	"	2030	15/30/45	Y/N	need 1 motor "
Univent	"	"	2035	15/30/45	Y/N	Fans not starting "
HVAC	Change air Trane	Roof "	2031	15/30/45	Y/N	Roof top "
HVAC	Change air Trane	Roof "	2032	15/30/45	Y/N	Roof top "
Univent	Eng Air VUV 1200	Classroom	2036	15/30/45	Y/N	"
HVAC	Change air Trane	Roof "	2040	15/30/45	Y/N	Roof top "
HVAC	change air Trane	Roof "	2042	15/30/45	Y/N	Roof top "
HVAC	Change air Trane	Roof "	2043	15/30/45	Y/N	Roof top "
HVAC	Change air Trane	Roof "	2044	15/30/45	Y/N	Roof top "
Univent	Eng Air VUV 1200	Classroom	2045	15/30/45	Y/N	"

AO Smith Mod DE3D437N
 115v 1100rpm Ser 2410871
 1.2amp 1/20Hp

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Univent	Eng Air VUV 1200	Classroom	2003	15/30/45	Y/N	Change filters, Checked operation oil motors
"	"	"	2008	15/30/45	Y/N	"
"	"	"	2007	15/30/45	Y/N	"
"	"	"	2004	15/30/45	Y/N	2 Motors Defective "
"	"	"	2009	15/30/45	Y/N	"
"	"	"	2006	15/30/45	Y/N	"
"	"	"	2014	15/30/45	Y/N	"
"	"	"	2015	15/30/45	Y/N	"
"	"	"	2021	15/30/45	Y/N	"
HVAC		Roof Classroom	2017	15/30/45	Y/N	Roof top "
Univent	Eng Air VUV 1200	Classroom	2022	15/30/45	Y/N	"
"	"	"	2023	15/30/45	Y/N	"
"	"	"	2018	15/30/45	Y/N	"

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
HVAC	Charge Air Trane	Roof Class Classroom	1099	15/30/45	Y/N	Change Filters. Checked operation oil motors
Univent	Eng Air VUV1200	Classroom		15/30/45	Y/N	Fans not running
k	u	u	1102	15/30/45	Y/N	1 Motor Defective
HVAC	Change air Trane	Roof Class Classroom	1097	15/30/45	Y/N	Leak in ceiling
Univent	Eng Air VUV1200	Classroom	1103	15/30/45	Y/N	u
Univent	2 Trane CDF3-5	u	1095	15/30/45	Y/N	needs 2-10x29x1 PL Filters
Univent	Eng Air VUV1200	u	1094	15/30/45	Y/N	u
u	u	u	1107	15/30/45	Y/N	1 Motor defective
u	u	u	1108	15/30/45	Y/N	u
u	u		1109	15/30/45	Y/N	u
u	u	u	1115	15/30/45	Y/N	u
u	u	u	1117	15/30/45	Y/N	u
u	1 Eng Air VUV1200 1 Eng Air VUV800	u	1112	15/30/45	Y/N	2 units one with 2x12x19x1 PL Filter

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Univent	Eng Air VUV 1200	Classroom	1089	15/30/45	Y/N	Changed filters, checked operation, oiled motors
"	"	"	1088	15/30/45	Y/N	"
"	"	"	1085	15/30/45	Y/N	"
"	"	"	1084	15/30/45	Y/N	"
"	"	"	"	15/30/45	Y/N	"
EF	Delhi	Roof	EF 96 42	15/30/45	Y/N	No disconnect, Belt worn
EF	Captive air	Roof	Hospitality Class	15/30/45	Y/N	Changed Belt
MAU	Captive air	"	Hospitality Class	15/30/45	Y/N	gas disconnect, tail not installed
EF	Dome EXH 010552	"	EF #3	15/30/45	Y/N	Belt OK
HVAC	Trane ACV006552	"	Drama Class	15/30/45	Y/N	Change filters, oil motor, checked operation
EF	Dome	"	EF 38	15/30/45	Y/N	checked Belts, lub motor
EF	Dome	"	EXH 012552	15/30/45	Y/N	"
EF	Dome	"	EXH 013552	15/30/45	Y/N	"

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
EF	Dome	Roof	EXH 033552	15/30/45	Y/N	checked Belt
EF	Dome	"	EXH 034552	15/30/45	Y/N	Unwired - not working
HVAC	Trane YSC120EWRHA0335	"	MUSIC ROOM	15/30/45	Y/N	NEW filters check operation. adjust belt
EF	Dome	"	EXH 036552	15/30/45	Y/N	
EF	Dome	"	RF 18	15/30/45	Y/N	
HVAC	TRANE	Roof	SAF SAF 001552 003552	15/30/45	Y/N	change filters checked operation lub. Motors
EF	Dome	"	EXH 035552	15/30/45	Y/N	
EF	Delhi	Roof	EXH 020552	15/30/45	Y/N	
HVAC	Trane	"	SAF 005552	15/30/45	Y/N	changed filters checked operation lub bearing / Motors
EF	Dome	"	EXH 021552	15/30/45	Y/N	Replace belt.
EF	MILL EXHAUST SHELDON	"	?	15/30/45	Y/N	
EF	Dome	"	EXH 023552	15/30/45	Y/N	
EF	Dome	"	EXH 024552	15/30/45	Y/N	Replace belt

✓
✓
✓

HWDSB	SCHOOL:	O'Harold Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
EF	Dome	Roof	V6	15/30/45	Y/N	
EF	Dome	"	EXH 025552	15/30/45	Y/N	Replace belt.
EF	Dome	"	EXN 026552	15/30/45	Y/N	Fan seized. motor trying to turn.
EF	Mill exhaust Dome Sheldon	"	EXH 027552	15/30/45	Y/N	None
EF	Mill Exhaust Sheldon	"	EXH 029552	15/30/45	Y/N	
EF	Dome	"	EXH 032552	15/30/45	Y/N	Belt changed Belt
EF	Dome	"	EF56	15/30/45	Y/N	Replace/Install belt.
EF	Dome	"	EF93	15/30/45	Y/N	replace belt.
EF	Dome	"	EF58	15/30/45	Y/N	motor not turning.
EF	Dome	"	EF67	15/30/45	Y/N	motor turning
EF	Dome	"	EF60	15/30/45	Y/N	motor not turning
EF	Dome	"	EF89	15/30/45	Y/N	motor not turning
EF	Dome	"	EF67	15/30/45	Y/N	switch broken

✓
✓
✓
✓
✓

382
 EXH 010552
 EXH 012552

HWDSB **SCHOOL:** *Orchard Park 55*

Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
EF	Greenheck CUE121-V6-4-X	Roof	EF 4	15/30/45	Y/N	direct drive ✓
EF	Mill Exhauster Sheldon	"	EF 64	15/30/45	Y/N	
EF	Greenheck CUE-121-V6-4-X	"	EF 5	15/30/45	Y/N	direct drive ✓
EF	Greenheck CUE-085-V6-X	"	EF 9	15/30/45	Y/N	direct drive ✓
EF	Delhi	"	?	15/30/45	Y/N	
EF	Greenheck CUE121-V6-4-X	"	EF 6	15/30/45	Y/N	direct drive ✓
EF	Dome	ROOF	EXH 007552	15/30/45	Y/N	Replaced belt. ✓
EF	Dome	Roof	EXH 006552	15/30/45	Y/N	replaced belt. ✓
EF	Dome	Roof	EXH 042552	15/30/45	Y/N	
EF	Dome	"	EF 68	15/30/45	Y/N	
EF	Dome	"	EF 74	15/30/45	Y/N	
EF	Dome	"	EXH 030552	15/30/45	Y/N	
EF	"	"	EXH 031552	15/30/45	Y/N	Sw. del. Brake ✓

Trane

SAFC06552

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
EK	Dome	Roof	EXH 014552	15/30/45	Y/N	Checked Belts - Change were necessary Lub. Bearings / motor
W	"	"	EXH 016552	15/30/45	Y/N	
SE	Dome	Roof	EXH 016552	15/30/45	Y/N	
BF	Delhi	"	SAF 004652	15/30/45	Y/N	
EF	Greenheck CUE121-V6-4-X	"	EF 1	15/30/45	Y/N	Direct drive
EF	Greenheck CUE085-V6-X	"	EF 7	15/30/45	Y/N	direct drive
EF	Greenheck CUE121-V6-4-X	"	EF 2	15/30/45	Y/N	direct drive
EK	Dome	"	EF 59	15/30/45	Y/N	replace belt.
EF	Mill Exhauster by SHELDON	"	EF 06	15/30/45	Y/N	direct drive
EF	Greenheck CUE121-V6-4-X	"	EF 3	15/30/45	Y/N	direct drive
EF	Greenheck CUE-085-V6-X	"	EF 8	15/30/45	Y/N	direct drive
EF	Greenheck CUE-141-V6-5-X	"	EF 10	15/30/45	Y/N	direct drive
EF	Greenheck CUE-141-V6-5-X	"	EF 11	15/30/45	Y/N	direct drive

✓
✓
✓
✓
✓
✓
✓
✓
✓
✓
✓

HWDSB	SCHOOL:	Orchard Park SS				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Univent	Eng Air VUV1200	Classroom	1119	15/30/45	Y/N	Changed filters, checked operation oil, motors
"	"	"	1120	15/30/45	Y/N	"
"	"	"	1121	15/30/45	Y/N	"
Univent	Commander airc	Offices	1003	15/30/45	Y/N	"
"	"	"	1004	15/30/45	Y/N	"
"	"	"	1004	15/30/45	Y/N	"
"	"	"	1004	15/30/45	Y/N	"
"	"	"	1004	15/30/45	Y/N	"
"	"	"	1004	15/30/45	Y/N	"
"	"	"	1004	15/30/45	Y/N	"
AHU	Trane	Music Mech Room	Gym	15/30/45	Y/N	Change filters greased checked Belts Bearings
AHU	Trane	"	Gym	15/30/45	Y/N	"
AHU	Trane	"	Cafe	15/30/45	Y/N	"