

HWDSB	SCHOOL:	Parkdale				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
AHU	Trane	Auditorium (stage)	Auditorium	15/30/45	Y/N	- Dirty filters 20x25x2 (4) - Belts - o.k. - checked operation
AHU	Trane	Auditorium (stage)	Auditorium	15/30/45	Y/N	- Dirty filters 20x25x2 (4) - Belts - o.k. - checked operation
Unit ventilator	Trane	Library	Rm 127 Library	15/30/45	Y/N	- checked filters → clean - checked operation
Unit ventilator		Library		15/30/45	Y/N	→ Cannot access → shelving built around them
U.V.	Trane	Rm 124	Rm 124	15/30/45	Y/N	→ switch broken on unit → filter clean.
U.V	Trane	Rm 104	Rm 104	15/30/45	Y/N	→ No power to unit → filter clean.
U.V	Trane	Rm 105	Rm 105	15/30/45	Y/N	→ filter clean → checked operation → o.k.
U.V	Trane	Rm 202	Rm 202	15/30/45	Y/N	→ filter clean → checked operation → o.k.
U.V	Trane	Rm 212	Rm 212	15/30/45	Y/N	→ filter clean → checked operation → o.k.
U.V	Trane	Rm 211	Rm 211	15/30/45	Y/N	→ filter clean → checked operation → o.k.
U.V	Trane	Rm 203	Rm 203	15/30/45	Y/N	→ filter clean → checked operation → o.k.
Unit ventilator	Change air	Portable	portable	15/30/45	Y/N	- checked Unit, checked filters, checked operation - o.k.
Unit ventilator	Change air	Portable	portable	15/30/45	Y/N	- checked operation, checked filters → o.k.

→ Need cover for thermostats (wo to come)

HWDSB	SCHOOL:		Parkdale school / Taply Town			
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
A/c	Comfort aire	Rm/05 Window	Rm/05	15/30/45	Y/N	Parkdale
A/c	Climette	Window	Staff Rm.	15/30/45	Y/N	Parkdale
				15/30/45	Y/N	
				15/30/45	Y/N	
	Taply Town	School		15/30/45	Y/N	
A/c	Comfort Air	Window	music Room	15/30/45	Y/N	- Filter dirty
Univent	System Air CAG1200 RAVPD	Portable	Portable	15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

No filters found on site.