

## PRINCE OF WALES

Equipment	Model/Serial	Location	What it Serves	Time Spent	Filters	Belts	Repairs Needed or Repaired
HP 3	Climate Master GSV018CGX40	Room 326A	Room 326	30 min			Needs Compressor, Contactor, HP Switch - Completed
HP 38	Climate Master GSV240AHX40	Room 313A	Room 213	30 min			
HP 39	Climate Master GSV030AHX40	Mechanical Room	Room 222	30 min			
Tower	Evap Co LRW-01-2	Mechanical Room		45 min			
SF 1	Greenheck RSF-150-S-X	High Roof	Mechanical Room	15 min			
EF 2	Greenheck RSF-170-B-X	High Roof		15 min			Motor Bearings loud - Completed
EF 5	Greenheck SWB-110-4-CW	High Roof		15 min			
HRU 1	EngAir FWB3S4-DG180-HR	High Roof	Multiple Areas	45 min			Restriction in Circuit A - Completed

Administrative 15 min