

3 1/2 hrs.

15 08  
30 7  
14

RL Hystop Elementary

HWDSB	SCHOOL:	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
Unit Ventilator	Change Air EPA 367000	Portable	Portable	15/30/45	Y/N	- Filters clean - operation → o.k.
E.F.15	Dome Fan	Roof	North - Rm 9	15/30/45	Y/N	- Running → o.k.
E.F.08	Dome Fan	Roof	South - KDG Library	15/30/45	Y/N	- Running → o.k.
E.F.07	Dome Fan	Roof	North Rm 3/10	15/30/45	Y/N	- Running → o.k.
E.F.14	Dome Fan Vapor Carnes	Roof	South - Gym	15/30/45	Y/N	- Running → o.k.
E.F.9	Dome Fan Vapor Carnes	Roof	South - Gym	15/30/45	Y/N	(slight vibration → bearings)
E.F.06	Dome Fan	Roof	North Rm 6/12	15/30/45	Y/N	- Running → o.k.
E.F.16	Dome Fan	Roof	South - Washrooms	15/30/45	Y/N	- Running - vibrating (bearings)
E.F.12	Dome Fan	Roof	Center/Rm west 6/13	15/30/45	Y/N	- Running. - Noisy.
E.F.11	Dome Fan	Roof	Center/Rm west 7/14	15/30/45	Y/N	- Not Running.
E.F.13	Dome Fan	Roof	South west - staff Rm	15/30/45	Y/N	- Running. o.k.
				15/30/45	Y/N	
				15/30/45	Y/N	

106214



HWDSB	SCHOOL:		R L Hyslop			
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
WU	Comfort airc	Window	OFFICE 119	15/30/45	Y/N	Unit Blows Breaker if set too high, Filters Clean
WU	Comfort airc	Window	Rm 216 Library	15/30/45	Y/N	Filters Clean, Checked operation - OK
EF	Expel-Airc	Wall	Rm 101	15/30/45	Y/N	Checked operation - OK
WU	Comfort airc	Window	Rm 214	15/30/45	Y/N	Unit is defective
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	