

SCHOOL NAME: Rosedale

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Complete	Immediate	Materials	Comments
change air- unit ventilator	CAE1000APAVPD	13601272B	portable	portable 2	30	N	2-16X20X1 pltd	good
change air - unit ventilator	CAE4036PAERWEDD	32581028C	portable	portable L008	30	Y	washable	main power off panel unit appears new
change air - unit ventilator	CAE4036PAERWEDD	31151317J	portable	portable L009	30	Y	washable	main power off panel unit appears new
AAON- RTU1	RN-0064000003L9	201706ANGF61995	roof	class rms	45	N	2-14X25X2 pltd	good
AAON-RTU2	RN-0064000003L9	201706ANGF61996	roof	class rms	45	Y	2-14X25X2pltd	wheel motor very hot and not operating
AAON- RTU3	RN-0064000003L9	201706ANGF61997	roof	class rms	45	Y	2-14X25X2 pltd	wheel motor not operating
EF-7	N/A	N/A	gym roof	gym	15	Y		no belt not operable unit very old
EF-8	N/A	N/A	gym roof	gym	15	y		belt needs replacing no size unit very old
EF- carnes	VUDK12P2A1CA20SPC1	422411.013	roof	class rms	15	N		good