

SCHOOL NAME: Ryerson

Unit Type and Tag	Model	Serial Number	Unit Location	Serves	Time to Complete Check (Minutes)	Requires Immediate Attention to Maintain Ventilation (Y/N)	Materials	Comments
Eng Air-RTU3	DJ-60-0	M11749SF3	roof	class rooms	45	Y	6-20X25X2 pltd 2-B49 2-B67	needs filters and belts
Eng Air-RTU2	DJ-60-0	M11749SF2	roof	class rooms	45	Y	9- 16X25X2 pltd 2-B52 2-B66	needs filters and belts, belts broken
Eng Air-RTU1	DJ-60-0	M11749SF1	roof	class rooms	45	Y	9-20X25X2 pltd 2-B56 2-B82	needs filters and belts , supply pulley very worn
EF5 - greenheck	GB0914X	708	roof	class rooms	15	Y	1-3L190	not operating and needs belt
EF6 - greenheck	GB1214X	708	roof	class rooms	15	y	1-3L200	not operating and needs belt
EF2 - greenheck	GB0816X	708	roof	class rooms	15	y	1-3L180	needs belt
EF4 - greenheck	GB0914X	708	roof	class rooms	15	y	1-3L190	not operating and needs belt
EF3 - greenheck	GB1314X	708	roof	class rooms	15	y	1-3L200	needs belt
EF1 - greenheck	GB1805X	708	roof	class rooms	15	y	1-A24	needs belt
EF7 - greenheck	GB0716X	708	roof	class rooms	15	y	1-3L210	not operating and needs belt
EF	N/A	N/A	gym roof	gym	15	y	1-A28	motor seized left off
EF	N/A	N/A	gym roof	gym	15	y		top cover missing, no belt , no power
SF2 - Sheldon	1H18	6942491	mech rm	gym	45	Y	2-B75 6-16X25X2pltd	replace filters, clean coil, clean return grilles high on wall lift required
window A/C	Fedders		library south	library south	15	Y	washable	no power to unit
window A/C	Fedders		library north	library north	15	N	washable	good
window A/C	Fedders		learning resource	learning resource	15	N	washable	good
change air - unit ventilator	CAE1000APAVPF	15830026H	portable	#20 rm 142 portable	30	N	2-16X20X1 pltd	good
change air - unit ventilator	CAE1000APAVPF	16110099K	portable	#23 rm 200 portable	30	N	washable	good
change air - unit ventilator	N/A	N/A	portable	#22 rm 188 portable	30	N	washable	good, unit name plate missing
change air - unit ventilator	CAE1000APAVPF	142400791	portable	#21	30	N	washable	good