

SCHOOL: SHERWOOD - 25 HIGH STREET

JOB: TMR-1749-16

UNIT TYPE AND TAG	MODEL	SERIAL	FILTER SIZE	BELT	UNIT LOCATION	SERVES	TIME TO COMPLETE	REQUIRES IMMEDIATE ATTENTION	NOTES
Exhaust Fan - Fan 25		7-984		A-24				ELECTRICAL DISCONNECT BROKEN	
Exhaust Fan - Fan 23				4L420				Belt replacement required	
Exhaust Fan - Fan 22				4L420				Belt replacement required	
Exhaust Fan - Fan 21				4L390		Washroom - boys 1st floor & 2nd Floor		Belt broken left in off position	
Exhaust Fan - Fan 10				AX40		Washroom - Staff			
Exhaust Fan - Fan 24				4L420		Center Washroom			
Exhaust Fan	Delhi			4L550				Blower pulley missing and no belt	
Main Return Fan				C195 (5)					
Main Supply Fan 1				C144 (4)				Belts need to be replaced	
Main Supply Fan 2				C144 (4)				Belts need to be replaced	
Exhaust Fan - Fan 31		6-900		4L420		Washroom/ Principle & Admin			
Supply Fan 9		SAF007564	(1)201 /2x56x2	A80 (2)		hallways			
Exhaust Fan 5		EXH011564	no filter racks	(2) B77		gym change rooms			
Supply Fan 3		SAF006564	(2) 40x20x2 (1)48x100x2	(3) B164		gym			
Return Fan 4		RAF002564	(2)40x80x2 (1)48x100x2	(3) B162		gym			
Supply air fan 8			(4) 20"x24"x2" pad	(2) B60		main foyer			
Dome Echaust Fan 1				A24				Belt replacement required	
Dome Echaust Fan 2				A24					