

Aug - 20/21
2020

HWDSB	SCHOOL:	Sir Allan McNab Secondary School				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
R.T.U.	Trane Voyager model TCD15K30ABB	Roof	office	15/30/45	Y/N	-replaced filters 20x25x2 (4) 20x20x2 (2)
Split Unit FC-2	Mitsubishi PKFY	Library Rm.1080	computer Room	15/30/45	Y/N	- cleaned filters, checked operation
Split Unit FC-3	Mitsubishi PKFY	Library Rm.1080	computer Room	15/30/45	Y/N	- cleaned filters, checked operation
Split Unit FC-4	Mitsubishi PKFY	Library Rm.1080	main Room	15/30/45	Y/N	- cleaned filters, checked operation
Split Unit FC-5	Mitsubishi PKFY	Library Rm.1080	Main Room	15/30/45	Y/N	- cleaned filters, checked operation
Split Unit FC-1	Mitsubishi PKFY	Library Room 1080	Library office	15/30/45	Y/N	- cleaned filters, checked operation
Split Unit FC-7	Mitsubishi PKFY	Library Rm. 1080	Library BOOK Room	15/30/45	Y/N	- checked operation - cleaned filters
Split Unit FC-6	Mitsubishi PKFY	Library Rm. 1080	Library Board Room	15/30/45	Y/N	- cleaned filters - checked operation
MAU	Captive Aire A2-D 500 - G15	Roof 1st floor	cafeteria	15/30/45	Y/N	-checked belts, fan
MAU	Captive Aire A2-D 500 - G15	Roof 1st floor	Kitchen	15/30/45	Y/N	- checked belts, fan
E.F Hood fan	Captive Aire DU180 - HFA	Roof 1st floor	Kitchen	15/30/45	Y/N	- checked unit
E.F Hood fan	Captive Aire DU180 HFA	Roof 1st floor	Cafeteria	15/30/45	Y/N	- checked unit
AHU.	Canadian Blower + Forge	Boiler Room	Shops	15/30/45	Y/N	-checked belts, checked filters -checked operation,

8.25
Thurs / Friday
Aug. 20/21
2020

HWDSB	SCHOOL:	Sir Allan McNab Secondary School				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
AHU	Canadian Blower and Forge Co.	Basement	Auditorium	15/30/45	Y/N	- Evap coil dirty - check ed belts - Air inlet grill dirty - checked filters - checked operation
AHU	Trane M series	Basement	Library + Cafe	15/30/45	Y/N	
AHU	Trane M series	Basement	Library Musical Room	15/30/45	Y/N	- Replaced Filters - belts o.k., checked operation
Return Fan	BR3 Canadian Blower + Forge	Basement	Library	15/30/45	Y/N	- Belts o.k.
Return Fan	Canadian Blower + Forge	Basement	Auditorium	15/30/45	Y/N	- Belts o.k. - checked operation
AHU	Canadian Blower and Forge Type H.V.	Room 2056 Mechanical Rm.	CS2 Boys Gym	15/30/45	Y/N	- Belts o.k., Filters clean - coil dirty - motor bearings noisy
AHU	Canadian Blower and Forge Type H.V.	Room 2056	CS1 Boys Gym	15/30/45	Y/N	- filters clean, belts o.k. - coil dirty -
AHU	Canadian Blower and Forge	Room 2056	CS4 Locker Room	15/30/45	Y/N	- Belts o.k., Filters clean.
AHU	Canadian Blower + Forge Type H.V.	Room 2056	CS3	15/30/45	Y/N	- Belts o.k., Filters clean. - coil dirty -
E.F	Canadian Blower + Forge - Aial Flow Fan	Room 2056	Locker Rooms	15/30/45	Y/N	- Not Working
AHU	Canadian Blower + Forge Model J	Room 2056	Shop	15/30/45	Y/N	- Replaced Filter, belts o.k. - checked operation.
Split Unit	Carrier	Room 1090	Dance studio	15/30/45	Y/N	- cleaned filters - checked operation
Split unit	Carrier	Room 2063	comm. Tech	15/30/45	Y/N	- cleaned filters - checked operation
Split Unit	Carrier 40MKCB22B...301	Room 1050	AH Ed or staff Room	30	N	- cleaned filters - checked operation

Thurs / Friday
Aug. 20/21
2020

HWDSB	SCHOOL:	Sir Allan McNab Secondary School				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
AHU - AS1	Canadian Blower + Forge P.C.M.	3rd floor mechanical Room	Perimeter class west	15/30/45	Y/N	- checked operation. - o.k. - Clean Filters, belts. - o.k
AHU - AS2	Canadian Blower + Forge P.C.M.	" "	Perimeter class East	15/30/45	Y/N	- checked Belts. - Filters clean. * - Supply fan does not start *
AHU - AS3	Canadian Blower + Forge P.C.M.	" "	Interior class East	15/30/45	Y/N	- checked belts, filters clean. - checked operation
FC2-39 VAV1-28	- Thermostat	wall	Room 3003	15/30/45	Y/N	- o.k
VAV1-29 FC2-40	- thermostat	wall	Room 3004	15/30/45	Y/N	- o.k
VAV-30 FC2-41	- Thermostat	wall	Room 3005	15/30/45	Y/N	- o.k
VAV2-27 FC2-46	- Thermostat	wall	Room 3006	15/30/45	Y/N	- o.k
VAV2-26 FC2-45	- Thermostat	wall	Room 3008	15/30/45	Y/N	- Need to check air supply
VAV2-25 FC2-44	- thermostat	wall	Room 3007	15/30/45	Y/N	- need to check air supply.
VAV1-27 FC2-38	- thermostat	wall	Room 3002	15/30/45	Y/N	- o.k.
Split Unit	Carrier 40MKCB54F...3	Room 1089	Kitchen Hospitality	15/30/45	Y/N	- cleaned filters
Split Unit	Carrier 40MKCB36F..	Room 1089	Kitchen Hospitality	15/30/45	Y/N	- cleaned filters
Split Unit	Carrier	Room 1089	Cafe	15/30/45	Y/N	- cleaned filters

HWDSB	SCHOOL:	Sir Allan McNab				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
VAV	VAV 2-18 FC2-19		Room 2037	15/30/45	Y/N	-O.K
	VAV 2-15 FC2-20		Rm 2035	15/30/45	Y/N	-O.K
	VAV 3-23 FC 2-36		Rm 2038	15/30/45	Y/N	-O.K
	VAV 3-20 FC2-33		Room 2039	15/30/45	Y/N	-O.K
	VAV 3-18 FC2-31		Room 2040	15/30/45	Y/N	-O.K
	VAV 3-17 FC 2-30		Room 2041	15/30/45	Y/N	-O.K
	VAV 3-16 FC2-29		Room 2010	15/30/45	Y/N	-O.K
	VAV 1-18 FC2-9		Room 2008	15/30/45	Y/N	-O.K
	VAV 1-19 FC2-10		Room 2008	15/30/45	Y/N	-O.K
	VAV 3-21 FC 2-34		Room 2012	15/30/45	Y/N	-O.K
				15/30/45	Y/N	Please Note: No ventilation working in Rooms 2047A, 2047B, 2048, 2049, 2051
				15/30/45	Y/N	
				15/30/45	Y/N	

Upper second
mechanical room

left wall