

HWDSB	SCHOOL: Sir Isaac Brook.					
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
UV	Greenheck 6-080-DSEx-QD	#1 Roof		15/30/45	Y/N	working.
UV	Greenheck 6-080-DSEx-QD	#2 Roof		15/30/45	Y/N	Not working / motor not turning
UV	Greenheck 6-080-DSEx-QD	#3 Roof		15/30/45	Y/N	Working
EF	Type LOISOS- LT3746/13	#6 Roof		15/30/45	Y/N	needed new belt. Replaced Belt. A4S Belt.
UV	Greenheck 6-0910-VS-x	#4 Roof		15/30/45	Y/N	working
UV	Greenheck G-095-DSEx-QD	#5 Roof		15/30/45	Y/N	Working
UV	Greenheck 6-103-VG-x	#7 on FFI Roof		15/30/45	Y/N	not running
UV	Greenheck G-070-DSEx-QD	#8 Roof		15/30/45	Y/N	working
UV	Greenheck G-090-DSEx-QD	#9 Roof	Boiler room office.	15/30/45	Y/N	working
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

Gir Isaac Brock

Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	SCHOOL:	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
AHU 1	Trane CSA4008VA300	Boilerroom	Classrooms	15/30/45	<input checked="" type="checkbox"/> Y/N	changed OK Belt OK Changed grease seals on Bearings clean
AHU 3	Trane CSA4003VA300	Boilerroom	Library	15/30/45	<input checked="" type="checkbox"/> Y/N	Filters changed, Belt changed grease seals on Bearings blown
UV/DX	Univent	Staffroom	Staffroom	15/30/45	<input checked="" type="checkbox"/> Y/N	washed filters checked operation automation off
UV	Univent	Computer LAB	Computer LAB	15/30/45	<input checked="" type="checkbox"/> Y/N	washed Filter checked operation
DX	Portless split Goodman	Computer LAB	Computer LAB	15/30/45	<input checked="" type="checkbox"/> Y/N	washed Filters checked operation - OK
Portable AHU	2	Office	Principals office	15/30/45	<input checked="" type="checkbox"/> Y/N	Filter Clean checked operation - OK
AHU 2	?	Storage Room	Gym	15/30/45	<input checked="" type="checkbox"/> Y/N	Belt was OK checked operation - OK 4x16x25x2 R Filters need changing
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	