

SIR WILFRID SCHOOL

Equipment	Model/Serial	Location	What it Serves	Time Spent	Filters	Belts	Repairs Needed or Repaired
RTU	Carrier 48HCRA04A2MBDT3CO / 2519C86549	Roof above classrooms	Classrooms New Addition	30 min			Adjusted loose belt
Return Fan	660J BLVS 89G1348H2T06	2nd Floor Mechanical Room	Hallways & Classrooms	45 min		(2of) 4L520	Motor pulley worn 5-3/8x1-1/8 shaft dual adjustable - needs belts - Completed
Return Fan	J-210VO 89G1348H2A05	2nd Floor Mechanical Room	Hallways & Classrooms	45 min		(1of) B85	Motor pulley worn 8-1/4 x 1-5/8 shaft fixed dual - needs Belt - Completed
Circ Pump 5	Water supply for SF3	2nd Floor Mechanical Room	2nd Floor hallways & Classrooms	15 min			Leaking seal & bearings assembly - Completed
MUA	Unknown	2nd Floor Mechanical Room	Hallways & Classrooms	30 min			Filters need to be replaced - unit off for piping job - Completed
Supply Fan 1&2		2nd Floor Mechanical Room	Hallways & Classrooms	30 min		(4of) 5V1060	Belts need to be replaced - Completed
Exhaust Fan 2	Greenheck SC120V6X / 12184772008	2nd Floor Mechanical Room	General Exhaust	15 min			Direct Drive slight vibration in duct
Exhaust Fan 3	Greenheck SWB1155CCWUBX / 121680591007	2nd Floor Mechanical Room	Multiple Areas	30 min			Slight vibration in duct

Administrative 20 min