

HWDSB	SCHOOL:		TAPLEY TOWN FILE			
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
EF	Dome 260	Roof	Gym	15/30/45	Y/N	Needs Belt and bearings
EF	Dome 259	Roof	Gym	15/30/45	Y/N	Needs Belt and bearings
EF	Dome 257	Roof	Washroom	15/30/45	Y/N	Needs Belt and bearings
EF	Dome 256	Roof	Washroom	15/30/45	Y/N	Belt worn, bearings worn has issue with motor
EF	Dome 255	Roof	Washroom	15/30/45	Y/N	Needs Belt and bearings
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

HWDSB	SCHOOL:	<del>Parkdale school</del> / Taply Town				
Unit Type and Tag (HVAC, AHU, EF, MAU, SF, etc.)	Model	Unit Loc. (Roof, Penthouse, Boiler Room, Corridor, etc.)	Serves (Offices, Foyer, Library, Staff Room, Classroom, Washroom, etc.)	Time To Complete Check (minutes)	Requires Immediate Attention to maintain ventilation	Comments
<del>A/c</del>	<del>Comfort aice</del>	<del>Rm/05 Window</del>	<del>Rm/05</del>	<del>15/30/45</del>	<del>Y/N</del>	<del>Parkdale</del>
<del>A/c</del>	<del>climette</del>	<del>window</del>	<del>staff Rm.</del>	<del>15/30/45</del>	<del>Y/N</del>	<del>Parkdale</del>
				15/30/45	Y/N	
				15/30/45	Y/N	
	Taply Town	School		15/30/45	Y/N	
A/c	Comfort Air	Window	music Room	15/30/45	Y/N	- Filter dirty
Univent	System Air CAG1200 RAVPD	Portable	Portable	15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	
				15/30/45	Y/N	

No filters found on site.